



ExamsNest

Your Ultimate Exam Preparation Hub

ExamsNest

Your Ultimate Exam Preparation Hub

Vendor: WELL AP

Code: WELL-AP

Exam: WELL Accredited Professional (WELL AP) Exam

<https://www.examsnest.com/exam/well-ap/>

QUESTIONS & ANSWERS

DEMO VERSION

QUESTIONS & ANSWERS
DEMO VERSION
(LIMITED CONTENT)

Version: 5.2

Question: 1

A WELL AP is reviewing a client's waste management plan for Feature X09: Waste Management. Which key requirement must be confirmed?

- A. Recycling containers are paired with waste receptacles
- B. Food waste is collected for on-site or off-site composting
- C. Protocols for managing and minimizing hazardous waste are included
- D. Cardboard, glass, paper, plastic and metals are collected for recycling

Answer: C

Explanation:

Feature X09 requires the safe management and minimization of wastes associated with hazardous chemicals present in commonly used products. Protocols for managing and minimizing hazardous waste are a key requirement for this feature.

Reference: = [WELL v2 Feature X09: Waste Management](#)

The key requirement for Feature X09: Waste Management within the WELL Building Standard is to have a waste management plan that includes protocols for managing and minimizing hazardous waste. This plan should cover the identification of roles, responsibilities, vendors for implementing the plan, sources of waste, strategies to minimize waste generation, waste collection strategies, protocols for cleaning spills of hazardous substances like mercury and pesticides, protocols to track, measure, and report waste stream flows, and protocols for off-site shipment of wastes.

Question: 2

A WELL AP is reviewing a zoning layout for a new WELL commercial fit-out project. Which of the following spaces should be labeled as acoustically quiet zones?

- A. Classrooms
- B. Lift lobbies
- C. Lactation rooms

D. Recreational rooms

Answer: C

Explanation:

According to the WELL v2 Feature S01: Sound Mapping, acoustically quiet zones include areas intended for concentration, wellness, rest, study and/or privacy. Lactation rooms fall under this category, as they provide a private and comfortable space for nursing mothers. Classrooms, lift lobbies and recreational rooms are not considered as quiet zones, as they are either mixed zones, circulation zones or loud zones respectively.

Reference: = [WELL v2 Feature S01: Sound Mapping](#)

Question: 3

The WELL AP notices mold and fungal growth on some indoor walls and ceilings of enclosed regularly occupied spaces. Which of the following is the most likely cause of the mold and fungal growth?

- A. Ducts were not properly sealed and protected during the construction stage
- B. Commissioning Agent did not confirm that the ventilation rate exceeds 21 cfm/person (10 L/s)
- C. Sensors were not installed in occupiable spaces to monitor dry-bulb temperature and relative humidity
- D. Mechanical system does not have the capability of maintaining relative humidity between 30% and 60% at all times

Answer: D

Explanation:

Feature X01 requires that the mechanical system has the capability of maintaining relative humidity between 30% and 60% at all times in all regularly occupied spaces. This is to prevent the growth of mold and other microorganisms that thrive in humid environments. Mold and fungal growth can cause health problems such as allergies, asthma, and infections. The other options are not directly related to the mold and fungal growth, although they may affect other aspects of indoor air quality.

Reference: = [WELL v2 Feature X01: Air Quality Standards](#)

Question: 4

Which of the following steps can be most effective in reducing antibiotics and pesticides in food?

- A. Limit red or processed meat items on the menu
- B. Offer main dish options that do not contain gluten

- C. Source at least 50% certified organic fruits and vegetables
- D. Provide heat resistant plastic plates, bowls, cups and utensils

Answer: C

Explanation:

Feature N03 aims to reduce the environmental and health impacts of food production by encouraging the use of organic, local, and seasonal food. Sourcing at least 50% certified organic fruits and vegetables can be most effective in reducing antibiotics and pesticides in food, as organic farming prohibits or restricts the use of synthetic chemicals and promotes natural methods of pest and disease control. The other options are not directly related to reducing antibiotics and pesticides in food, although they may have other benefits or drawbacks for health and sustainability.

Reference: = [WELL v2 Feature N03: Responsible Food Production](#), [World leaders and experts call for significant reduction in the use of antimicrobial drugs in global food systems](#), [Three things needed to curb antibiotic and pesticide resistance](#)

Question: 5

What should the minimum size be for a restorative space in a project with 30 regular occupants to comply with Feature M07: Restorative Spaces?

- A. 32 ft² (3 m²)
- B. 100 ft² (9 m²)
- C. 105 ft² (10 m²)
- D. 194 ft² (18 m²)

Answer: C

Explanation:

According to the WELL v2 Feature M07, the minimum size of a restorative space is 75 ft² plus 1 ft² per regular occupant, up to a maximum of 800 ft². For a project with 30 regular occupants, the minimum size would be $75 + 30 = 105$ ft² (or $7 + 0.1 \times 30 = 10$ m²).

Reference: = [WELL v2 Feature M07: Restorative Spaces](#)



ExamsNest

Your Ultimate Exam Preparation Hub

Thank You for trying the PDF Demo

Vendor: WELL AP

Code: WELL-AP

Exam: WELL Accredited Professional (WELL AP) Exam

<https://www.examsnest.com/exam/well-ap/>

Use Coupon “**SAVE15**” for extra 15% discount on the purchase of Practice Test Software. Test your Exam preparation with actual exam questions.

Start Your Preparation